



Certificate of Compliance

Certificate: 1668679 (10990-47)

Master Contract: 165491

Project: 2610085

Date Issued: April 8, 2013

Issued to: Elektron Technology UK Ltd

**Broers Building
JJ Thomson Avenue
Cambridge, CB3 0FA
United Kingdom
Attention: Vivian Benest**

The products listed below are eligible to bear the CSA Mark shown with adjacent indicators 'C' and 'US' for Canada and US or with adjacent indicator 'US' for US only or without either indicator for Canada only.



John Lam

Issued by: John Lam

PRODUCTS

CLASS 6241 10 - SWITCHES - Snap - Special Use

Switches, special use, manual, toggle with bat-handle actuator (plastic or metal), rated 250V, 60Hz, Series 17XX:

Ratings:

1700, 1710, single pole, 20A @ 250V ac N.I., 1 hp @ 250V ac, 1/2 hp @ 125V ac;

1720, single pole, 20A @ 250V ac N.I., 1/2 hp @ 250V ac, 1/4 hp @ 125V ac;

1750, 1760, double pole, 16A @ 250V ac N.I., 1hp @ 250V ac, 1/2 hp @ 125V ac;

1770, double pole, 16A @ 250V ac N.I., 1/2 hp @ 250V ac, 1/4 hp @ 125V ac;

1784, 1789, single pole, 5A @ 250V ac. N.I.

Note: Model designations may have prefix and suffix letters.

APPLICABLE REQUIREMENTS



Certificate: 1668679 (10990-47)

Master Contract: 165491

Project: 2610085

Date Issued: April 8, 2013

CSA Std C22.2 No. 55-M1986 - Special Use Switches

ANSI/UL Std No. 1054 - Special-Use Switches